

ADDENDUM NO. 1  
TO  
PLANS AND SPECIFICATIONS  
FOR  
HILO WASTEWATER TREATMENT PLANT  
FLOW METER REPLACEMENT  
JOB NO. WW-3687  
AT  
SOUTH HILO, HAWAI'I  
COUNTY AND STATE OF HAWAI'I

**NOTICE TO ALL PROSPECTIVE BIDDERS:**

The items listed below are made a part of the contract and shall govern the work, taking precedence over the previously issued plans and specifications governing the particular item of work mentioned.

**MANDATORY PRE-BID CONFERENCE SUMMARY:**

The following attached documents summarize discussions and clarifications provided during the Mandatory Pre-Bid Conference conducted on September 13, 2006 for the project.

- Mandatory Pre-Bid Meeting Minutes
- Mandatory Pre-Bid Meeting Agenda
- Minimum Contractor Licensing Requirements for Project
- Mandatory Pre-Bid Meeting Roster

**PROJECT SPECIFICATIONS:**

- Specifications Section 01010-1.01.C: Add "Costs for WWD personnel involved in the shut-down of flows to the HWWTP and for all electrical work will be borne by the County."
- Specifications Section 01010-1.01.D: Add Paragraph 1.01.D to read as follows: "D. Information provided by the vendor on September 12, 2006 indicates that the Estimated Time of Arrival (ETA) for the County-supplied Flowmeter is November 14, 2006. The Construction Schedule provided for the Project shall be based on the current ETA of the Flowmeter. Additional time will be granted the Contractor in the event of the failure of the County-supplied Flowmeter to arrive by its scheduled date."

- Specifications Section 01310-3.01: Add Paragraph 3.01.D to read as follows: “D. Failure of the Contractor to complete work within the maximum allowed 3 hour shut-down may result in a Sewage Spill to State Waters and the Contractor will be responsible for any and all costs related to the Sewage Spill including any and all penalties which may be levied by the State of Hawai‘i Department of Health (DOH), Federal Environmental Protection Agency (EPA), and/or any other regulatory agencies.”

**REQUEST FOR INFORMATION (RFI):**

- An RFI was issued requesting verification on whether the requirements of Section 01000-14.06 applies to the project and it is confirmed that the section applies to the project.
- An RFI was issued proposing an alternate pipe support detail. Pipe supports shall be as specified in the project documents.

---

Bruce C. McClure, P.E.  
 Director, Department of Public Works  
 County of Hawai‘i

Date Issued: September 18, 2006

Please detach and execute receipt below and return immediately to the Administration Office, Department of Public Works, County of Hawai‘i, Hilo, Hawai‘i.

-----  
 Receipt of Addendum No. 1 for HILO WASTEWATER TREATMENT PLANT FLOW  
 METER REPLACEMENT, Job No. WW-3687, South Hilo, Hawai‘i, is hereby acknowledged.

Signed \_\_\_\_\_ Title \_\_\_\_\_

Firm \_\_\_\_\_ Date \_\_\_\_\_